

CERTIFICATE

Issued to:

Applicant:

Grup İmaj Aydınlatma San. Tic. A.Ş

Bayirkoy Beldesi, Fatih Mahallesi, Kucuk Sanayi, 1.

Sokak No:17

34520 Bilecik, Türkiye

Licensee:

Grup İmaj Aydınlatma San. Tic. A.Ş

Bayirkoy Beldesi, Fatih Mahallesi, Kucuk Sanayi, 1.

Sokak No:17

34520 Bilecik, Türkiye

Product : Ignitor for sodium and metal halide lamps

Trade name(s) : İMAJ

Type(s)/model(s) : İM03, İM03T, İM04 and İM04T

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 61347-1:2015, EN 61347-1:2015/A1:2021, EN 61347-2-1:2001, EN 61347-2-1:2001/A1:2006, EN 61347-2-1:2001/A2:2014, EN 60927:2007 and EN 60927:2007/A1:2013
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6069227


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 14 February 2025 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-153955

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Susan Lehner
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Ignitor for sodium and metal halide lamps
Trade name(s)	: IMAJ
Type(s)/model(s)	: IM03, IM03T, IM04 and IM04T
Rated voltage	: 220 - 240 Vac
Rated frequency	: 50/60 Hz
Ambient temperature range(ta)	: -25 / +85 °C
Max. case temperature (tc)	: 95 /105 °C

Product data – type IM03 and IM03T

Rated power	: 35 – 70 W
Supply current	: Max 2A

Product data – type IM04 and IM04T

Rated power	: 100 - 400 W or 35 – 400 W
Supply current	: Max 4,5A

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN 61347-2-1:2001
EN 61347-2-1:2001/A1:2006
EN 61347-2-1:2001/A2:2014
EN 60927:2007
EN 60927:2007/A1:2013

Test result

The test results are documented in DEKRA test file 621310300.

Additional information

The list of components is laid down in test report 6213103.50 and 6213103.51.

Conclusion

The examination has confirmed that all requirements were met.

Factory location

Grup Imaj Aydınlatma San. Tic. A.S
Bayirkoy Beldesi, Fatih Mahallesi, Kucuk Sanayi, 1. Sokak No:17
34520 Bilecik, Türkiye